



Type testing

Solid fuel boilers acc. EN 303-5:2012

Test of the heating requirements, test report C

Boiler manufacturer/Contractor: Extraflame S.p.A
Via dell'Artigianato, 12
I-36030 Montecchio Precalcino (VI)

Type designation: HP15
HP22
HP30

Type of construction: Heating boilers in accordance with EN303-5

Type of loading: Automatically

Burner type: -

Type of fuel: Wood pellets

No.	Type designation	Nominal load Output [kW] Wood pellets	Heat Input [kW] Wood pellets
1	HP15	4,4 – 15,2	5,0 – 16,9
2	HP22	6,6 – 22,5	7,4 – 25,0
3	HP30	8,6 – 31,0	9,5 – 33,9

Test basis:

According EN 303-5:2012, cl.4.4 Heating requirements.

This examination has been carried out by the impartial test centre of TÜV Rheinland in a test laboratory equipped in accordance with DIN EN 304, version 01/04.

Remarks: -

Test result:

The boilers are in conformity to the emission class 5, EN 303-5:2012, cl. 4.4.7, the efficiency class 5, EN 303-5:2012, cl. 4.4.2 and cl. 4.4 Heating requirements.

The requirements of the above-mentioned standards are fulfilled. The local, applicable installation conditions to be observed.

Cologne, 07.04.2014
432/mc
Expert


Dipl.-Ing. M. Ciccarelli

Test Centre for Energy Appliances
DIN- und DVGW-Laboratory
Deputy Head of Test Centre


Dipl.-Ing. R. Verbert