

# DECLARATION



**TÜV erklærer hermed at apparatet til bolig, mal træpiller som brændsel:**  
TÜV hereby declares that the heating boiler for solid fuels fired by wood pellets:

**Brændeovn / Heating boilers:** Heating boilers for solid fuels  
**Model / Model:** **HP15, HP22, HP30**  
**Konstrueret af / Manufactured by:** **Extraflame S.p.A**  
Via dell'Artigianato, 12  
I-36030 Montecchio Precalcino (VI)

Har bestået afprøvningstesten af type (ITT) der vises i den tekniske overensstemmelsesrapport, i henhold til bestemmelserne:

Comply with the initial type test (ITT) indicated in the test report, according to the standard:

## DIN EN 303-5:2012

Rapport om teknisk overensstemmelse nr:

Test report no.:

**K 1169 2013 T1 / T2**

Navn udstyr (appliance name)	Effekt (Heat output)	Produktion [%] (Efficiency [%])	Termisk effect [kW] (Heat output [kW])			Støvparkler Dust * [mg/m³ (13% O₂)]	CO [mg/m³] 13% O₂	OGC [mg/m³] 13% O₂
			Total (Total)	I miljøet (To space)	I vandet (To water)			
HP15	Nominal Nominal	90,02	15,21	-	15,21	14,4	88,5	8,9
	Reduced Reduced	88,58	4,42	-	4,42	31,5	242,6	8,7
HP22	Nominal Nominal	90,04	22,54	-	22,54	19,7	139,2	0,5
	Reduced Reduced	88,84	6,61	-	6,61	46,8	315,3	3,9
HP30	Nominal Nominal	91,45	31,03	-	31,03	14,5	76,2	1,5
	Reduced Reduced	90,48	8,64	-	8,64	31,7	257,0	1,5

\*) manual gravimetric method acc. EN 13284-1

På baggrund af ovennævnte partikelemissionen attesteres det hermed, at fyringsanlægget opfylder emissionskravene i bilag 1 til Bekendtgørelse nr. 1432 af 11/12/2007 vedr. regulering af luftforurening fra brændeovne og brændekedler samt visse andre faste anlæg til energiproduktion.

Based on the above stated emissions it hereby is certified that the boiler installation fulfills the requirements for emissions in appendix 1 from the Announcement no. 1432 of 11/12/2007 concerning the regulation of air pollution from heat stoves and wood log boilers.

Cologne 07.04.2014 432/mc	Test Centre for Energy Appliances DIN EN ISO/IEC 17025:2005 accreditation: DAKS D-PL-11120-04-00	Reserved for the chimney sweeper Skorstensfejerspåtegning
Expert  Dipl. Ing. M. Ciccarelli	Deputy Head of Test Centre  Dipl.-Ing. R. Verben	